

GUARDIAN SYSTEMS, INC.

1108 Ashville Road
P.O. Box 190
Leeds, Alabama 35094

Telephone (205) 699-6647
Toll Free (866) 729-7211
Fax (205) 699-3882

Page 1 of 9

City of Leeds
City of Leeds
1040 Park Drive
Leeds, AL 35094
Attention: Mr. Brad Watson

Report Date: 06/22/2018
Receive Date: 06/07/2018
Receive Time: 10:30

Control No : 1806-00112 Sample # 001
Sampler : DL
Sample ID: LC-MP-3

Sample Date: 06/07/2018
Sample Time: 8:35


Laboratory Certificate

PARAMETER	RESULTS	UNITS	ANALYST	DATE	TIME	METHOD	REF
pH	7.52	SU	JB	06/07/2018	8:35	150.1	(1)
Turbidity, Nephelometric	2.22	NTU	JB	06/07/2018	8:35	180.1	
Conductance, Sp. (field)	397	umhos	JB	06/07/2018	8:35	120.1	(1)
Nitrogen, Ammonia	<0.1	mg/L	TLB	06/21/2018	17:04	350.2	(1)
Color, APHA	21	PCU	AH	06/08/2018	16:18	110.2	(1)
Hardness, Total	225	mg/L	DRH	06/14/2018	10:00	200.7	
Calcium	76.2	mg/L	DRH	06/14/2018	10:00	200.7	(1)
Magnesium	8.45	mg/L	DRH	06/14/2018	10:00	200.7	(1)
Potassium	1.84	mg/L	DRH	06/14/2018	10:00	200.7	(1)

This Certificate is Continued On Next Page.

METHOD REFERENCES

1. Methods for Chemical Analysis of Water and Wastes. EPA-600/4-79-20, revised March 1983, August 1993 May 1994
2. Standard Methods for the Examination of Water and Waste Water, 18th, 19th, 20th, and 22nd Edition, 2012
3. Test Methods for Evaluating Solid Wastes Physical Chemical Method SW-846, 3rd Edition, Updated IV December 1996
4. 1987 ASTM Annual Standards
5. Code of Federal Regulations, Title 40, Part 136, Appendix A, Revised July 1995
6. Methods for the Determination of Organic Compounds in Drinking Water, EPA-600/4-88/039, Revised July 1991, August 1995
7. NIOSH Manual of Analytical Methods, 4th Edition, May 1996



GUARDIAN SYSTEMS, INC.

1108 Ashville Road
P.O. Box 190
Leeds, Alabama 35094

Telephone (205) 699-6647
Toll Free (866) 729-7211
Fax (205) 699-3882

Page 2 of 9

City of Leeds
City of Leeds
1040 Park Drive
Leeds, AL 35094
Attention: Mr. Brad Watson

Report Date: 06/22/2018
Receive Date: 06/07/2018
Receive Time: 10:30

Control No : 1806-00112 Sample # 002
Sampler : JB
Sample ID: LC-MP-2

Sample Date: 06/07/2018
Sample Time: 8:41


Laboratory Certificate

PARAMETER	RESULTS	UNITS	ANALYST	DATE	TIME	METHOD	REF
pH	7.52	SU	JB	06/07/2018	8:41	150.1	(1)
Turbidity, Nephelometric	1.68	NTU	JB	06/07/2018	8:41	180.1	
Conductance, Sp. (field)	408	umhos	JB	06/07/2018	8:41	120.1	(1)
Nitrogen, Ammonia	<0.1	mg/L	TLB	06/21/2018	17:04	350.2	(1)
Color, APHA	19.	PCU	AH	06/08/2018	16:18	110.2	(1)
Hardness, Total	223.	mg/L	DRH	06/14/2018	10:00	200.7	
Calcium	75.4	mg/L	DRH	06/14/2018	10:00	200.7	(1)
Magnesium	8.53	mg/L	DRH	06/14/2018	10:00	200.7	(1)
Potassium	1.77	mg/L	DRH	06/14/2018	10:00	200.7	(1)

This Certificate is Continued On Next Page.

METHOD REFERENCES

1. Methods for Chemical Analysis of Water and Wastes. EPA-600/4-79-20, revised March 1983, August 1993 May 1994
2. Standard Methods for the Examination of Water and Waste Water, 18th, 19th, 20th, and 22nd Edition, 2012
3. Test Methods for Evaluating Solid Wastes Physical Chemical Method SW-846, 3rd Edition, Updated IV December 1996
4. 1987 ASTM Annual Standards
5. Code of Federal Regulations, Title 40, Part 136, Appendix A, Revised July 1995
6. Methods for the Determination of Organic Compounds in Drinking Water, EPA-600/4-88/039, Revised July 1991, August 1995
7. NIOSH Manual of Analytical Methods, 4th Edition, May 1996



GUARDIAN SYSTEMS, INC.

1108 Ashville Road
P.O. Box 190
Leeds, Alabama 35094

Telephone (205) 699-6647
Toll Free (866) 729-7211
Fax (205) 699-3882

Page 3 of 9

City of Leeds
City of Leeds
1040 Park Drive
Leeds, AL 35094
Attention: Mr. Brad Watson

Report Date: 06/22/2018
Receive Date: 06/07/2018
Receive Time: 10:30

Control No : 1806-00112 Sample # 003
Sampler : JB
Sample ID: LC-MP-1

Sample Date: 06/07/2018
Sample Time: 8:46


Laboratory Certificate

PARAMETER	RESULTS	UNITS	ANALYST	DATE	TIME	METHOD	REF
pH	7.54	SU	JB	06/07/2018	8:46	150.1	(1)
Turbidity, Nephelometric	1.27	NTU	JB	06/07/2018	8:55	180.1	
Conductance, Sp. (field)	401	umhos	JB	06/07/2018	8:46	120.1	(1)
Nitrogen, Ammonia	<0.1	mg/L	TLB	06/21/2018	17:04	350.2	(1)
Color, APHA	21.	PCU	AH	06/08/2018	16:18	110.2	(1)
Hardness, Total	217.	mg/L	DRH	06/14/2018	10:00	200.7	
Calcium	73.8	mg/L	DRH	06/14/2018	10:00	200.7	(1)
Magnesium	7.84	mg/L	DRH	06/14/2018	10:00	200.7	(1)
Potassium	1.68	mg/L	DRH	06/14/2018	10:00	200.7	(1)

This Certificate is Continued On Next Page.

METHOD REFERENCES

1. Methods for Chemical Analysis of Water and Wastes. EPA-600/4-79-20, revised March 1983, August 1993 May 1994
2. Standard Methods for the Examination of Water and Waste Water, 18th, 19th, 20th, and 22nd Edition, 2012
3. Test Methods for Evaluating Solid Wastes Physical Chemical Method SW-846, 3rd Edition, Updated IV December 1996
4. 1987 ASTM Annual Standards
5. Code of Federal Regulations, Title 40, Part 136, Appendix A, Revised July 1995
6. Methods for the Determination of Organic Compounds in Drinking Water, EPA-600/4-88/039, Revised July 1991, August 1995
7. NIOSH Manual of Analytical Methods, 4th Edition, May 1996



GUARDIAN SYSTEMS, INC.

1108 Ashville Road
P.O. Box 190
Leeds, Alabama 35094

Telephone (205) 699-6647
Toll Free (866) 729-7211
Fax (205) 699-3882

Page 4 of 9

City of Leeds
City of Leeds
1040 Park Drive
Leeds, AL 35094
Attention: Mr. Brad Watson

Report Date: 06/22/2018
Receive Date: 06/07/2018
Receive Time: 10:30

Control No : 1806-00112 Sample # 004
Sampler : JB
Sample ID: LC-SS-6

Sample Date: 06/07/2018
Sample Time: 8:55


Laboratory Certificate

PARAMETER	RESULTS	UNITS	ANALYST	DATE	TIME	METHOD	REF
pH	7.48	SU	JB	06/07/2018	8:55	150.1	(1)
Turbidity, Nephelometric	1.62	NTU	JB	06/07/2018	8:55	180.1	
Conductance, Sp. (field)	390	umhos	JB	06/07/2018	8:55	120.1	(1)
Nitrogen, Ammonia	<0.1	mg/L	TLB	06/21/2018	17:04	350.2	(1)
Color, APHA	22.	PCU	AH	06/08/2018	16:18	110.2	(1)
Hardness, Total	209.	mg/L	DRH	06/14/2018	10:00	200.7	
Calcium	71.2	mg/L	DRH	06/14/2018	10:00	200.7	(1)
Magnesium	7.49	mg/L	DRH	06/14/2018	10:00	200.7	(1)
Potassium	2.08	mg/L	DRH	06/14/2018	10:00	200.7	(1)

This Certificate is Continued On Next Page.

METHOD REFERENCES

1. Methods for Chemical Analysis of Water and Wastes. EPA-600/4-79-20, revised March 1983, August 1993 May 1994
2. Standard Methods for the Examination of Water and Waste Water, 18th, 19th, 20th, and 22nd Edition, 2012
3. Test Methods for Evaluating Solid Wastes Physical Chemical Method SW-846, 3rd Edition, Updated IV December 1996
4. 1987 ASTM Annual Standards
5. Code of Federal Regulations, Title 40, Part 136, Appendix A, Revised July 1995
6. Methods for the Determination of Organic Compounds in Drinking Water, EPA-600/4-88/039, Revised July 1991, August 1995
7. NIOSH Manual of Analytical Methods, 4th Edition, May 1996



GUARDIAN SYSTEMS, INC.

1108 Ashville Road
P.O. Box 190
Leeds, Alabama 35094

Telephone (205) 699-6647
Toll Free (866) 729-7211
Fax (205) 699-3882

Page 5 of 9

City of Leeds
City of Leeds
1040 Park Drive
Leeds, AL 35094
Attention: Mr. Brad Watson

Report Date: 06/22/2018
Receive Date: 06/07/2018
Receive Time: 10:30

Control No : 1806-00112 Sample # 005
Sampler : JB
Sample ID: LC-SS-7

Sample Date: 06/07/2018
Sample Time: 9:02


Laboratory Certificate

PARAMETER	RESULTS	UNITS	ANALYST	DATE	TIME	METHOD	REF
pH	7.88	SU	JB	06/07/2018	9:02	150.1	(1)
Turbidity, Nephelometric	1.75	NTU	JB	06/07/2018	9:02	180.1	
Conductance, Sp. (field)	386	umhos	JB	06/07/2018	9:02	120.1	(1)
Nitrogen, Ammonia	<0.1	mg/L	TLB	06/21/2018	17:04	350.2	(1)
Color, APHA	25	PCU	AH	06/08/2018	16:18	110.2	(1)
Hardness, Total	203	mg/L	DRH	06/14/2018	10:00	200.7	
Calcium	69.8	mg/L	DRH	06/14/2018	10:00	200.7	(1)
Magnesium	6.89	mg/L	DRH	06/14/2018	10:00	200.7	(1)
Potassium	2.48	mg/L	DRH	06/14/2018	10:00	200.7	(1)

This Certificate is Continued On Next Page.

METHOD REFERENCES

1. Methods for Chemical Analysis of Water and Wastes. EPA-600/4-79-20, revised March 1983, August 1993 May 1994
2. Standard Methods for the Examination of Water and Waste Water, 18th, 19th, 20th and 22nd Edition, 2012
3. Test Methods for Evaluating Solid Wastes Physical Chemical Method SW-846, 3rd Edition, Updated IV December 1996
4. 1987 ASTM Annual Standards
5. Code of Federal Regulations, Title 40, Part 136, Appendix A, Revised July 1995
6. Methods for the Determination of Organic Compounds in Drinking Water, EPA-600/4-88/039, Revised July 1991, August 1995
7. NIOSH Manual of Analytical Methods, 4th Edition, May 1996



GUARDIAN SYSTEMS, INC.

1108 Ashville Road
P.O. Box 190
Leeds, Alabama 35094

Telephone (205) 699-6647
Toll Free (866) 729-7211
Fax (205) 699-3882

Page 6 of 9

City of Leeds
City of Leeds
1040 Park Drive
Leeds, AL 35094
Attention: Mr. Brad Watson

Report Date: 06/22/2018
Receive Date: 06/07/2018
Receive Time: 10:30

Control No : 1806-00112 Sample # 006
Sampler : JB
Sample ID: LC-SS-9

Sample Date: 06/07/2018
Sample Time: 9:14


Laboratory Certificate

PARAMETER	RESULTS	UNITS	ANALYST	DATE	TIME	METHOD	REF
pH	7.68	SU	JB	06/07/2018	9:14	150.1	(1)
Turbidity, Nephelometric	2.11	NTU	JB	06/07/2018	9:14	180.1	
Conductance, Sp. (field)	400	umhos	JB	06/07/2018	9:14	120.1	(1)
Nitrogen, Ammonia	<0.1	mg/L	TLB	06/21/2018	17:04	350.2	(1)
Color, APHA	29.	PCU	AH	06/08/2018	16:18	110.2	(1)
Hardness, Total	203.	mg/L	DRH	06/14/2018	10:00	200.7	
Calcium	69.2	mg/L	DRH	06/14/2018	10:00	200.7	(1)
Magnesium	7.27	mg/L	DRH	06/14/2018	10:00	200.7	(1)
Potassium	2.75	mg/L	DRH	06/14/2018	10:00	200.7	(1)

This Certificate is Continued On Next Page.

METHOD REFERENCES

1. Methods for Chemical Analysis of Water and Wastes. EPA-600/4-79-20, revised March 1983, August 1993 May 1994
2. Standard Methods for the Examination of Water and Waste Water, 18th, 19th, 20th, and 22nd Edition, 2012
3. Test Methods for Evaluating Solid Wastes Physical Chemical Method SW-846, 3rd Edition, Updated IV December 1996
4. 1987 ASTM Annual Standards
5. Code of Federal Regulations, Title 40, Part 136, Appendix A, Revised July 1995
6. Methods for the Determination of Organic Compounds in Drinking Water, EPA-600/4-88/039, Revised July 1991, August 1995
7. NIOSH Manual of Analytical Methods, 4th Edition, May 1996



GUARDIAN SYSTEMS, INC.

1108 Ashville Road
P.O. Box 190
Leeds, Alabama 35094

Telephone (205) 699-6647
Toll Free (866) 729-7211
Fax (205) 699-3882

Page 7 of 9

City of Leeds
City of Leeds
1040 Park Drive
Leeds, AL 35094
Attention: Mr. Brad Watson

Report Date: 06/22/2018
Receive Date: 06/07/2018
Receive Time: 10:30

Control No : 1806-00112 Sample # 007
Sampler : JB
Sample ID: LC-SS-10

Sample Date: 06/07/2018
Sample Time: 9:18


Laboratory Certificate

PARAMETER	RESULTS	UNITS	ANALYST	DATE	TIME	METHOD	REF
pH	7.63	SU	JB	06/07/2018	9:18	150.1	(1)
Turbidity, Nephelometric	2.06	NTU	JB	06/07/2018	9:18	180.1	
Conductance, Sp. (field)	401	umhos	JB	06/07/2018	9:18	120.1	(1)
Nitrogen, Ammonia	<0.1	mg/L	TLB	06/21/2018	17:04	350.2	(1)
Color, APHA	26.	PCU	AH	06/08/2018	16:18	110.2	(1)
Hardness, Total	205.	mg/L	DRH	06/14/2018	10:00	200.7	
Calcium	69.8	mg/L	DRH	06/14/2018	10:00	200.7	(1)
Magnesium	7.35	mg/L	DRH	06/14/2018	10:00	200.7	(1)
Potassium	2.85	mg/L	DRH	06/14/2018	10:00	200.7	(1)

This Certificate is Continued On Next Page.

METHOD REFERENCES

1. Methods for Chemical Analysis of Water and Wastes. EPA-600/4-79-20, revised March 1983, August 1993 May 1994
2. Standard Methods for the Examination of Water and Waste Water, 18th, 19th, 20th, and 22nd Edition, 2012
3. Test Methods for Evaluating Solid Wastes Physical Chemical Method SW-846, 3rd Edition, Updated IV December 1996
4. 1987 ASTM Annual Standards
5. Code of Federal Regulations, Title 40, Part 136, Appendix A, Revised July 1995
6. Methods for the Determination of Organic Compounds in Drinking Water, EPA-600/4-88/039, Revised July 1991, August 1995
7. NIOSH Manual of Analytical Methods, 4th Edition, May 1996



GUARDIAN SYSTEMS, INC.

1108 Ashville Road
P.O. Box 190
Leeds, Alabama 35094

Telephone (205) 699-6647
Toll Free (866) 729-7211
Fax (205) 699-3882

Page 8 of 9

City of Leeds
City of Leeds
1040 Park Drive
Leeds, AL 35094
Attention: Mr. Brad Watson

Report Date: 06/22/2018
Receive Date: 06/07/2018
Receive Time: 10:30

Control No : 1806-00112 Sample # 008
Sampler : JB
Sample ID: DC-SS-3

Sample Date: 06/07/2018
Sample Time: 9:30


Laboratory Certificate

PARAMETER	RESULTS	UNITS	ANALYST	DATE	TIME	METHOD	REF
pH	7.35	SU	JB	06/07/2018	9:30	150.1	(1)
Turbidity, Nephelometric	2.57	NTU	JB	06/07/2018	9:30	180.1	
Conductance, Sp. (field)	456	umhos	JB	06/07/2018	9:30	120.1	(1)
Color, APHA	32.	PCU	AH	06/08/2018	16:18	110.2	(1)
Nitrogen, Ammonia	<0.1	mg/L	TLB	06/21/2018	17:04	350.2	(1)
Calcium	82.0	mg/L	DRH	06/14/2018	10:00	200.7	(1)
Magnesium	8.72	mg/L	DRH	06/14/2018	10:00	200.7	(1)
Potassium	11.3	mg/L	DRH	06/14/2018	10:00	200.7	(1)
Hardness, Total	241.	mg/L	DRH	06/14/2018	10:00	200.7	

This Certificate is Continued On Next Page.

METHOD REFERENCES

1. Methods for Chemical Analysis of Water and Wastes. EPA-600/4-79-20, revised March 1983, August 1993 May 1994
2. Standard Methods for the Examination of Water and Waste Water, 18th, 19th, 20th, and 22nd Edition, 2012
3. Test Methods for Evaluating Solid Wastes Physical Chemical Method SW-846, 3rd Edition, Updated IV December 1996
4. 1987 ASTM Annual Standards
5. Code of Federal Regulations, Title 40, Part 136, Appendix A, Revised July 1995
6. Methods for the Determination of Organic Compounds in Drinking Water, EPA-600/4-88/039, Revised July 1991, August 1995
7. NIOSH Manual of Analytical Methods, 4th Edition, May 1996



GUARDIAN SYSTEMS, INC.

1108 Ashville Road
P.O. Box 190
Leeds, Alabama 35094

Telephone (205) 699-6647
Toll Free (866) 729-7211
Fax (205) 699-3882

Page 9 of 9

City of Leeds
City of Leeds
1040 Park Drive
Leeds, AL 35094
Attention: Mr. Brad Watson

Report Date: 06/22/2018
Receive Date: 06/07/2018
Receive Time: 10:30

Control No : 1806-00112 Sample # 009
Sampler : DL
Sample ID: DC-SS-4

Sample Date: 06/07/2018
Sample Time: 9:35

Laboratory Certificate

PARAMETER	RESULTS	UNITS	ANALYST	DATE	TIME	METHOD	REF
No Flow, No Sample					0:00		

Approved By: *Sinda Lee Miller*
TMB

METHOD REFERENCES

1. Methods for Chemical Analysis of Water and Wastes. EPA-600/4-79-20, revised March 1983, August 1993 May 1994
2. Standard Methods for the Examination of Water and Waste Water, 18th, 19th, 20th, and 22nd Edition, 2012
3. Test Methods for Evaluating Solid Wastes Physical Chemical Method SW-846, 3rd Edition, Updated IV December 1996
4. 1987 ASTM Annual Standards
5. Code of Federal Regulations, Title 40, Part 136, Appendix A, Revised July 1995
6. Methods for the Determination of Organic Compounds in Drinking Water, EPA-600/4-88/039, Revised July 1991, August 1995
7. NIOSH Manual of Analytical Methods, 4th Edition, May 1996

(205) 699-3882 Fax
www.qsilab.com

Put an "X" in the appropriate column for sample type and sample preservative. Write in analysis requested.

Guardian Systems, Inc.

1108 Ashville Road, P.O. Box 190
Leeds, Alabama 35094
(205) 699-6647
email: gsi@gsilab.com

Chain of Custody Record/ Analysis Report

(205) 699-3882 Fax
www.gsilab.com



Client: Mr. Brad Watson		Phone:					
Company: City of Leeds		Fax:					
Address: 1040 Park Drive		P.O.#:					
Leeds, AL 35094		Project: 2018 1 st Semester Stormwater-Dry					
Sample ID	Sample Description	Sample Date	Sample Time	Sample * Comp.	Sample Bottle	Sample Preservative	Analysis Requested
LCMP1	#3	6/7/18	8:46		Grab		
					Glass		
					Plastic		
					HCl		
					HNO ₃		
					H ₂ SO ₄		
					NaOH		
					Cool 4°C		
					Other **		
							Field pH: 7.54
							Field Turbidity: 1.27
							Field Conductivity: 401.5
				X			APHA Color
				X			Ammonia
				X			Hardness. Ca. Mg. K
LCSS6	#4	6/7/18	8:55				Field pH: 7.48
							Field Turbidity: 1.62
							Field Conductivity: 390.5
				X			APHA Color
				X			Ammonia
				X			Hardness. Ca. Mg. K
Sampled by: Jesse Blair		Relinquished by: Jesse Blair		Date: 6/7/18		Time: 10:30	
Received by: [Signature]		Relinquished by: [Signature]		Date: [Blank]		Time: [Blank]	
Received for Laboratory by: [Signature]		Relinquished by: [Signature]		Date: [Blank]		Time: [Blank]	
Was Shipped Container intact when received? Yes [X] No []		Seals intact? Yes [X] No []		Date: 6/7/18		Time: 10:30	
Were all samples properly preserved? Yes [X] No []		Initials [Signature]		Sample temp. 6 °C			
Comments: Other = See Above for Sample Preservatives, Field Measurements							

Put an "X" in the appropriate column for sample type and sample preservative. Write in analysis requested.

* For composite samples include start and stop date and time in comments section **Write in preservative used in comments

Guardian Systems, Inc.

1108 Ashville Road, P.O. Box 190
Leeds, Alabama 35094
(205) 699-6647
email: gsi@gsilab.com

Chain of Custody Record/ Analysis Report

(205) 699-3882 Fax
www.gsilab.com



Client: Mr. Brad Watson		Phone:														
Company: City of Leeds		Fax:														
Address: 1040 Park Drive		P.O.#:														
Leeds, AL 35094		Project: 2018 1 st Semester Stormwater- Dry														
Sample ID	Sample Description	Sample Date	Sample Time	Comp. *	Grab	Glass	Plastic	HCl	HNO ₃	H ₂ SO ₄	NaOH	Cool 4°C	Other **	Analysis Requested		
LCSS7	#5	6/7/18	9:02												Field pH: 7.88	
															Field Turbidity: 1.75	
															Field Conductivity: 386 uS	
				X		X									APHA Color	
				X		X									Ammonia	
				X		X									Hardness. Ca. Mg. K	
LCSS9	#6	6/7/18	9:14												Field pH: 7.68	
															Field Turbidity: 2.11	
															Field Conductivity: 400 uS	
				X		X									APHA Color	
				X		X									Ammonia	
				X		X									Hardness. Ca. Mg. K	
Sampled by: Jesse Blair		Date: 6/7/18		Time: 10:30		Relinquished by: Jesse Blair		Date: 6/7/18		Time: 10:30						
Received by:		Date:		Time:		Relinquished by:		Date:		Time:						
Received for Laboratory by: Shari Poyner		Date: 6/7/18		Time: 10:30		Relinquished by:		Date:		Time:						
Was Shipped Container intact when received?		Yes		No		Seals intact?		Yes		No						
Were all samples properly preserved?		Yes		No		Sample temp.		6		°C						
Comments: Other = See Above for Sample Preservatives, Field Measurements																

Put an "X" in the appropriate column for sample type and sample preservative. Write in analysis requested.

* For composite samples include start and stop date and time in comments section **Write in preservative used in comments



Guardian Systems, Inc.

1108 Ashville Road, P.O. Box 190
Leeds, Alabama 35094
(205) 699-6647
email: gsi@gsilab.com

Chain of Custody Record/ Analysis Report

(205) 699-3882 Fax
www.gsilab.com



Client: Mr. Brad Watson		Phone:					
Company: City of Leeds		Fax:					
Address: 1040 Park Drive		P.O.#:					
Leeds, AL 35094		Project: 2018 1 st Semester Stormwater- Dry					
Sample ID	Sample Description	Sample Date	Sample Time	Sample * Comp.	Sample Bottle	Sample Preservative	Analysis Requested
DCSS4	#9	6/7/18	9:35		Grab	Plastic	
						HCl	
						HNO ₃	
						H ₂ SO ₄	
						NaOH	
						Cool 4°C	
						Other **	
							Field pH: NO FLOW
							Field Turbidity:
							Field Conductivity:
				X			APHA Color
				X			Ammonia
				X			Hardness. Ca. Mg. K
							Field pH:
							Field Turbidity:
							Field Conductivity:
				X			APHA Color
				X			Ammonia
				X			Hardness. Ca. Mg. K
Sampled by: Jesse Blair		Date: 6/7/18		Time: 10:30			
Received by: Jesse Blair		Date: 6/7/18		Time: 10:30			
Received by: Jesse Blair		Date: 6/7/18		Time: 10:30			
Received for Laboratory by: Jesse Blair		Date: 6/7/18		Time: 10:30			
Was Shipped Container intact when received? Yes ☒ No ☐		Seals intact? Yes ☒ No ☐		Sample temp. 6 °C			
Were all samples properly preserved? Yes ☒ No ☐		Initials JB		Time: 10:30			
Comments: Other = See Above for Sample Preservatives, Field Measurements							

Put an "X" in the appropriate column for sample type and sample preservative. Write in analysis requested.

* For composite samples include start and stop date and time in comments section **Write in preservative used in comments