

GUARDIAN SYSTEMS, INC.

1108 Ashville Road
P.O. Box 190
Leeds, Alabama 35094

Telephone (205) 699-6647
Toll Free (866) 729-7211
Fax (205) 699-3882

Page 1 of 9

City of Leeds
City of Leeds
1040 Park Drive
Leeds, AL 35094
Attention: Mr. Brad Watson

Report Date: 04/30/2020
Receive Date: 04/22/2020
Receive Time: 15:25

Control No : 2004-00340 Sample # 001
Sampler : DL
Sample ID: DC-33-3

Sample Date: 04/22/2020
Sample Time: 11:50


Laboratory Certificate

PARAMETER	RESULTS	UNITS	ANALYST	DATE	TIME	METHOD	REF
pH	7.15	SU	DL	04/22/2020	11:50	150.1	(1)
Turbidity, Nephelometric	16.10	NTU	DL	04/22/2020	11:50	180.1	
Conductance, Sp. (field)	180.	umhos	DL	04/22/2020	11:50	120.1	(1)
Nitrogen, Ammonia	<0.1	mg/L	JH	04/27/2020	14:16	350.2	(1)
Color, APHA	<10.	PCU	ML	04/22/2020	16:35	110.2	
Hardness, Total	67.	mg/L	DRH	04/27/2020	12:00	200.7	
Calcium	21.1	mg/L	DRH	04/27/2020	12:00	200.7	(1)
Magnesium	3.47	mg/L	DRH	04/27/2020	12:00	200.7	(1)
Potassium	1.39	mg/L	DRH	04/27/2020	12:00	200.7	(1)

This Certificate is Continued On Next Page.

METHOD REFERENCES

1. Methods for Chemical Analysis of Water and Wastes. EPA-600/4-79-20, revised March 1983, August 1993 May 1994
2. Standard Methods for the Examination of Water and Waste Water, 18th, 19th, 20th, and 22nd Edition, 2012
3. Test Methods for Evaluating Solid Wastes Physical Chemical Method SW-846, 3rd Edition, Updated IV December 1996
4. 1987 ASTM Annual Standards
5. Code of Federal Regulations, Title 40, Part 136, Appendix A, Revised July 1995
6. Methods for the Determination of Organic Compounds in Drinking Water, EPA-600/4-88/039, Revised July 1991, August 1995
7. NIOSH Manual of Analytical Methods, 4th Edition, May 1996



GUARDIAN SYSTEMS, INC.

1108 Ashville Road
P.O. Box 190
Leeds, Alabama 35094

Telephone (205) 699-6647
Toll Free (866) 729-7211
Fax (205) 699-3882

Page 2 of 9

City of Leeds
City of Leeds
1040 Park Drive
Leeds, AL 35094
Attention: Mr. Brad Watson

Report Date: 04/30/2020
Receive Date: 04/22/2020
Receive Time: 15:25

Control No : 2004-00340 Sample # 002
Sampler : DB
Sample ID: DC-SS-4

Sample Date: 04/22/2020
Sample Time: 11:40


Laboratory Certificate

PARAMETER	RESULTS	UNITS	ANALYST	DATE	TIME	METHOD	REF
pH	7.10	SU	DL	04/22/2020	11:40	150.1	(1)
Turbidity, Nephelometric	16.00	NTU	DL	04/22/2020	11:40	180.1	
Conductance, Sp. (field)	181.	umhos	DL	04/22/2020	11:40	120.1	(1)
Nitrogen, Ammonia	<0.1	mg/L	JH	04/27/2020	14:16	350.2	(1)
Color, APHA	10.	PCU	ML	04/22/2020	16:35	110.2	
Hardness, Total	67.	mg/L	DRH	04/27/2020	12:00	200.7	
Calcium	21.2	mg/L	DRH	04/27/2020	12:00	200.7	(1)
Magnesium	3.48	mg/L	DRH	04/27/2020	12:00	200.7	(1)
Potassium	1.40	mg/L	DRH	04/27/2020	12:00	200.7	(1)

This Certificate is Continued On Next Page.

METHOD REFERENCES

1. Methods for Chemical Analysis of Water and Wastes, EPA-600/4-79-20, revised March 1983, August 1993 May 1994
2. Standard Methods for the Examination of Water and Waste Water, 18th, 19th, 20th, and 22nd Edition, 2012
3. Test Methods for Evaluating Solid Wastes Physical Chemical Method SW-846, 3rd Edition, Updated IV December 1996
4. 1987 ASTM Annual Standards
5. Code of Federal Regulations, Title 40, Part 136, Appendix A, Revised July 1995
6. Methods for the Determination of Organic Compounds in Drinking Water, EPA-600/4-88/039, Revised July 1991, August 1995
7. NIOSH Manual of Analytical Methods, 4th Edition, May 1996



GUARDIAN SYSTEMS, INC.

1108 Ashville Road
P.O. Box 190
Leeds, Alabama 35094

Telephone (205) 699-6647
Toll Free (866) 729-7211
Fax (205) 699-3882

Page 3 of 9

City of Leeds
City of Leeds
1040 Park Drive
Leeds, AL 35094
Attention: Mr. Brad Watson

Report Date: 04/30/2020
Receive Date: 04/22/2020
Receive Time: 15:25

Control No : 2004-00340 Sample # 003
Sampler : DL
Sample ID: LC-MP-3

Sample Date: 04/22/2020
Sample Time: 12:05


Laboratory Certificate

PARAMETER	RESULTS	UNITS	ANALYST	DATE	TIME	METHOD	REF
pH	7.30	SU	DL	04/22/2020	12:05	150.1	(1)
Turbidity, Nephelometric	7.05	NTU	DL	04/22/2020	12:05	180.1	
Conductance, Sp. (field)	311.	umhos	DL	04/22/2020	12:05	120.1	(1)
Nitrogen, Ammonia	<0.1	mg/L	JH	04/27/2020	14:16	350.2	(1)
Color, APHA	10.	PCU	ML	04/22/2020	16:35	110.2	
Hardness, Total	153.	mg/L	DRH	04/27/2020	12:00	200.7	
Calcium	52.8	mg/L	DRH	04/27/2020	12:00	200.7	(1)
Magnesium	5.09	mg/L	DRH	04/27/2020	12:00	200.7	(1)
Potassium	1.31	mg/L	DRH	04/27/2020	12:00	200.7	(1)

This Certificate is Continued On Next Page.

METHOD REFERENCES

1. Methods for Chemical Analysis of Water and Wastes. EPA-600/4-79-20, revised March 1983, August 1993 May 1994
2. Standard Methods for the Examination of Water and Waste Water, 18th, 19th, 20th, and 22nd Edition, 2012
3. Test Methods for Evaluating Solid Wastes Physical Chemical Method SW-846, 3rd Edition, Updated IV December 1996
4. 1987 ASTM Annual Standards
5. Code of Federal Regulations, Title 40, Part 136, Appendix A, Revised July 1995
6. Methods for the Determination of Organic Compounds in Drinking Water, EPA-600/4-88/039, Revised July 1991, August 1995
7. NIOSH Manual of Analytical Methods, 4th Edition, May 1996



GUARDIAN SYSTEMS, INC.

1108 Ashville Road
P.O. Box 190
Leeds, Alabama 35094

Telephone (205) 699-6647
Toll Free (866) 729-7211
Fax (205) 699-3882

Page 4 of 9

City of Leeds
City of Leeds
1040 Park Drive
Leeds, AL 35094
Attention: Mr. Brad Watson

Report Date: 04/30/2020
Receive Date: 04/22/2020
Receive Time: 15:25

Control No : 2004-00340 Sample # 004
Sampler : DL
Sample ID: LC-MP-2

Sample Date: 04/22/2020
Sample Time: 12:12


Laboratory Certificate

PARAMETER	RESULTS	UNITS	ANALYST	DATE	TIME	METHOD	REF
pH	7.36	SU	DL	04/22/2020	12:12	150.1	(1)
Turbidity, Nephelometric	10.00	NTU	DL	04/22/2020	12:12	180.1	
Conductance, Sp. (field)	310.	umhos	DL	04/22/2020	12:12	120.1	(1)
Nitrogen, Ammonia	<0.1	mg/L	JH	04/27/2020	14:16	350.2	(1)
Color, APHA	<10.	PCU	ML	04/22/2020	16:35	110.2	
Hardness, Total	146.	mg/L	DRH	04/27/2020	12:00	200.7	
Calcium	50.3	mg/L	DRH	04/27/2020	12:00	200.7	(1)
Magnesium	4.85	mg/L	DRH	04/27/2020	12:00	200.7	(1)
Potassium	1.29	mg/L	DRH	04/27/2020	12:00	200.7	(1)

This Certificate is Continued On Next Page.

METHOD REFERENCES

1. Methods for Chemical Analysis of Water and Wastes. EPA-600/4-79-20, revised March 1983, August 1993 May 1994
2. Standard Methods for the Examination of Water and Waste Water, 18th, 19th, 20th, and 22nd Edition, 2012
3. Test Methods for Evaluating Solid Wastes Physical Chemical Method SW-846, 3rd Edition, Updated IV December 1996
4. 1987 ASTM Annual Standards
5. Code of Federal Regulations, Title 40, Part 136, Appendix A, Revised July 1995
6. Methods for the Determination of Organic Compounds in Drinking Water, EPA-600/4-88/039, Revised July 1991, August 1995
7. NIOSH Manual of Analytical Methods, 4th Edition, May 1996



GUARDIAN SYSTEMS, INC.

1108 Ashville Road
P.O. Box 190
Leeds, Alabama 35094

Telephone (205) 699-6647
Toll Free (866) 729-7211
Fax (205) 699-3882

Page 5 of 9

City of Leeds
City of Leeds
1040 Park Drive
Leeds, AL 35094
Attention: Mr. Brad Watson

Report Date: 04/30/2020
Receive Date: 04/22/2020
Receive Time: 15:25

Control No : 2004-00340 Sample # 005
Sampler : DL
Sample ID: LC-MP-1

Sample Date: 04/22/2020
Sample Time: 12:20


Laboratory Certificate

PARAMETER	RESULTS	UNITS	ANALYST	DATE	TIME	METHOD	REF
pH	7.40	SU	DL	04/22/2020	12:20	150.1	(1)
Turbidity, Nephelometric	6.78	NTU	DL	04/22/2020	12:20	180.1	
Conductance, Sp. (field)	303.	umhos	DL	04/22/2020	12:20	120.1	(1)
Nitrogen, Ammonia	0.19	mg/L	JH	04/27/2020	14:16	350.2	(1)
Color, APHA	<10.	PCU	ML	04/22/2020	16:35	110.2	
Hardness, Total	144.	mg/L	DRH	04/27/2020	12:00	200.7	
Calcium	50.0	mg/L	DRH	04/27/2020	12:00	200.7	(1)
Magnesium	4.72	mg/L	DRH	04/27/2020	12:00	200.7	(1)
Potassium	1.23	mg/L	DRH	04/27/2020	12:00	200.7	(1)

This Certificate is Continued On Next Page.

METHOD REFERENCES

1. Methods for Chemical Analysis of Water and Wastes. EPA-600/4-79-20, revised March 1983, August 1993 May 1994
2. Standard Methods for the Examination of Water and Waste Water, 18th, 19th, 20th, and 22nd Edition, 2012
3. Test Methods for Evaluating Solid Wastes Physical Chemical Method SW-846, 3rd Edition, Updated IV/December 1996
4. 1987 ASTM Annual Standards
5. Code of Federal Regulations, Title 40, Part 136, Appendix A, Revised July 1995
6. Methods for the Determination of Organic Compounds in Drinking Water, EPA-600/4-88/039, Revised July 1991, August 1995
7. NIOSH Manual of Analytical Methods, 4th Edition, May 1996



GUARDIAN SYSTEMS, INC.

1108 Ashville Road
P.O. Box 190
Leeds, Alabama 35094

Telephone (205) 699-6647
Toll Free (866) 729-7211
Fax (205) 699-3882

Page 6 of 9

City of Leeds
City of Leeds
1040 Park Drive
Leeds, AL 35094
Attention: Mr. Brad Watson

Report Date: 04/30/2020
Receive Date: 04/22/2020
Receive Time: 15:25

Control No : 2004-00340 Sample # 006
Sampler : DL
Sample ID: LC-SS-6

Sample Date: 04/22/2020
Sample Time: 12:32


Laboratory Certificate

PARAMETER	RESULTS	UNITS	ANALYST	DATE	TIME	METHOD	REF
pH	7.38	SU	DL	04/22/2020	12:32	150.1	(1)
Turbidity, Nephelometric	9.57	NTU	DL	04/22/2020	12:32	180.1	
Conductance, Sp. (field)	288.	umhos	DL	04/22/2020	12:32	120.1	(1)
Nitrogen, Ammonia	0.14	mg/L	JH	04/27/2020	14:16	350.2	(1)
Color, APHA	13.	PCU	ML	04/22/2020	16:35	110.2	
Hardness, Total	135.	mg/L	DRH	04/27/2020	12:00	200.7	
Calcium	46.7	mg/L	DRH	04/27/2020	12:00	200.7	(1)
Magnesium	4.35	mg/L	DRH	04/27/2020	12:00	200.7	(1)
Potassium	1.12	mg/L	DRH	04/27/2020	12:00	200.7	(1)

This Certificate is Continued On Next Page.

METHOD REFERENCES

1. Methods for Chemical Analysis of Water and Wastes. EPA-600/4-79-20, revised March 1983, August 1993 May 1994
2. Standard Methods for the Examination of Water and Waste Water, 18th, 19th, 20th, and 22nd Edition, 2012
3. Test Methods for Evaluating Solid Wastes Physical Chemical Method SW-846, 3rd Edition, Updated IV December 1996
4. 1987 ASTM Annual Standards
5. Code of Federal Regulations, Title 40, Part 136, Appendix A, Revised July 1995
6. Methods for the Determination of Organic Compounds in Drinking Water, EPA-600/4-88/039, Revised July 1991, August 1995
7. NIOSH Manual of Analytical Methods, 4th Edition, May 1996



GUARDIAN SYSTEMS, INC.

1108 Ashville Road
P.O. Box 190
Leeds, Alabama 35094

Telephone (205) 699-6647
Toll Free (866) 729-7211
Fax (205) 699-3882

Page 7 of 9

City of Leeds
City of Leeds
1040 Park Drive
Leeds, AL 35094
Attention: Mr. Brad Watson

Report Date: 04/30/2020
Receive Date: 04/22/2020
Receive Time: 15:25

Control No : 2004-00340 Sample # 007
Sampler : DB
Sample ID: LC-SS-7

Sample Date: 04/22/2020
Sample Time: 12:39


Laboratory Certificate

PARAMETER	RESULTS	UNITS	ANALYST	DATE	TIME	METHOD	REF
pH	7.46	SU	DL	04/22/2020	12:39	150.1	(1)
Turbidity, Nephelometric	9.12	NTU	DL	04/22/2020	12:39	180.1	
Conductance, Sp. (field)	277.	umhos	DL	04/22/2020	12:39	120.1	(1)
Nitrogen, Ammonia	0.20	mg/L	JH	04/27/2020	14:16	350.2	(1)
Color, APHA	13.	PCU	ML	04/22/2020	16:35	110.2	
Hardness, Total	135.	mg/L	DRH	04/27/2020	12:00	200.7	
Calcium	47.0	mg/L	DRH	04/27/2020	12:00	200.7	(1)
Magnesium	4.27	mg/L	DRH	04/27/2020	12:00	200.7	(1)
Potassium	1.18	mg/L	DRH	04/27/2020	12:00	200.7	(1)

This Certificate is Continued On Next Page.

METHOD REFERENCES

1. Methods for Chemical Analysis of Water and Wastes. EPA-600/4-79-20, revised March 1983, August 1993 May 1994
2. Standard Methods for the Examination of Water and Waste Water, 18th, 19th, 20th, and 22nd Edition, 2012
3. Test Methods for Evaluating Solid Wastes Physical Chemical Method SW-846, 3rd Edition, Updated IV December 1996
4. 1987 ASTM Annual Standards
5. Code of Federal Regulations, Title 40, Part 136, Appendix A, Revised July 1995
6. Methods for the Determination of Organic Compounds in Drinking Water, EPA-600/4-88/039, Revised July 1991, August 1995
7. NIOSH Manual of Analytical Methods, 4th Edition, May 1996



GUARDIAN SYSTEMS, INC.

1108 Ashville Road
P.O. Box 190
Leeds, Alabama 35094

Telephone (205) 699-6647
Toll Free (866) 729-7211
Fax (205) 699-3882

Page 8 of 9

City of Leeds
City of Leeds
1040 Park Drive
Leeds, AL 35094
Attention: Mr. Brad Watson

Report Date: 04/30/2020
Receive Date: 04/22/2020
Receive Time: 15:25

Control No : 2004-00340 Sample # 008
Sampler : DL
Sample ID: LC-SS-9

Sample Date: 04/22/2020
Sample Time: 12:50


Laboratory Certificate

PARAMETER	RESULTS	UNITS	ANALYST	DATE	TIME	METHOD	REF
pH	7.50	SU	DL	04/22/2020	12:50	150.1	(1)
Turbidity, Nephelometric	10.60	NTU	DL	04/22/2020	12:50	180.1	
Conductance, Sp. (field)	260.	umhos	DL	04/22/2020	12:50	120.1	(1)
Color, APHA	19.	PCU	ML	04/22/2020	16:35	110.2	
Nitrogen, Ammonia	<0.1	mg/L	JH	04/27/2020	14:16	350.2	(1)
Calcium	43.8	mg/L	DRH	04/27/2020	12:00	200.7	(1)
Magnesium	4.21	mg/L	DRH	04/27/2020	12:00	200.7	(1)
Potassium	1.31	mg/L	DRH	04/27/2020	12:00	200.7	(1)
Hardness, Total	127.	mg/L	DRH	04/27/2020	12:00	200.7	

This Certificate is Continued On Next Page.

METHOD REFERENCES

1. Methods for Chemical Analysis of Water and Wastes. EPA-600/4-79-20, revised March 1983, August 1993 May 1994
2. Standard Methods for the Examination of Water and Waste Water, 18th, 19th, 20th, and 22nd Edition, 2012
3. Test Methods for Evaluating Solid Wastes Physical Chemical Method SW-846, 3rd Edition, Updated IV December 1996
4. 1987 ASTM Annual Standards
5. Code of Federal Regulations, Title 40, Part 136, Appendix A, Revised July 1995
6. Methods for the Determination of Organic Compounds in Drinking Water, EPA-600/4-88/039, Revised July 1991, August 1995
7. NIOSH Manual of Analytical Methods, 4th Edition, May 1996



GUARDIAN SYSTEMS, INC.

1108 Ashville Road
P.O. Box 190
Leeds, Alabama 35094

Telephone (205) 699-6647
Toll Free (866) 729-7211
Fax (205) 699-3882

Page 9 of 9

City of Leeds
City of Leeds
1040 Park Drive
Leeds, AL 35094
Attention: Mr. Brad Watson

Report Date: 04/30/2020
Receive Date: 04/22/2020
Receive Time: 15:25

Control No : 2004-00340 Sample # 009
Sampler : DL
Sample ID: LC-SS-10

Sample Date: 04/22/2020
Sample Time: 13:00

Laboratory Certificate

PARAMETER	RESULTS	UNITS	ANALYST	DATE	TIME	METHOD	REF
pH	7.53	SU	DL	04/22/2020	13:00	150.1	(1)
Turbidity, Nephelometric	10.22	NTU	DL	04/22/2020	13:00	180.1	
Conductance, Sp. (field)	252.	umhos	DL	04/22/2020	13:00	120.1	(1)
Color, APHA	13.	PCU	ML	04/22/2020	16:35	110.2	
Nitrogen, Ammonia	0.22	mg/L	JH	04/27/2020	14:16	350.2	(1)
Calcium	45.2	mg/L	DRH	04/27/2020	12:00	200.7	(1)
Magnesium	4.32	mg/L	DRH	04/27/2020	12:00	200.7	(1)
Potassium	1.18	mg/L	DRH	04/27/2020	12:00	200.7	(1)
Hardness, Total	131.	mg/L	DRH	04/27/2020	12:00	200.7	

Approved By: Smiles Lopez Mello

METHOD REFERENCES

1. Methods for Chemical Analysis of Water and Wastes. EPA-600/4-79-20, revised March 1983, August 1993 May 1994
2. Standard Methods for the Examination of Water and Waste Water, 18th, 19th, 20th, and 22nd Edition, 2012
3. Test Methods for Evaluating Solid Wastes Physical Chemical Method SW-846, 3rd Edition, Updated IV December 1996
4. 1987 ASTM Annual Standards
5. Code of Federal Regulations, Title 40, Part 136, Appendix A, Revised July 1995
6. Methods for the Determination of Organic Compounds in Drinking Water, EPA-600/4-88/039, Revised July 1991, August 1995
7. NIOSH Manual of Analytical Methods, 4th Edition, May 1996



Chain of Custody Record/ Analysis Report

1108 Ashville Road, P.O. Box 190
Leeds, Alabama 35094
(205) 699-6647
email: gsi@gsilab.com

(205) 699-3882 Fax
www.gsilab.com

Client: Mr. Brad Watson		Phone:	
Company: City of Leeds		Fax:	
Address: 1040 Park Drive		P.O.#:	
Leeds, AL 35094		Project: 2020 1st Semester Stormwater- Dry	

Sample ID	Sample Description	Sample Date	Sample Time	Sample Preservative					Analysis Requested					
				Comp.*	Glass	Plastic	HCl	HNO ₃	H ₂ SO ₄	NaOH	Cool 4°C	Other **	Field pH:	Field Turbidity:
DC-SSB		4/22	1150											
				X		X								
				X		X								
				X		X								
				X		X								
DC-SS4		4/22	1140											
				X		X								
				X		X								
				X		X								

Sampled by: Dennis P. Lyons Relinquished by: [Signature] Date: 22 Apr 20 Time: 1525

Received by: [Signature] Relinquished by: [Signature] Date: Time: Date: Time:

Received by: [Signature] Relinquished by: [Signature] Date: 22 Apr 20 Time: 1525

Was Shipped Container intact when received? Yes ☒ No ☐ Seals intact? Yes ☒ No ☐

Were all samples properly preserved? Yes ☒ No ☐ Sample temp. 6 °C

Comments: Other = See Above for Sample Preservatives, Field Measurements

PH Meter Calibration Info		Buffer Traceability #		Exp. Date		QC Sample		Technician Information	
Buffer #:	4.00	NRE19092702		9/2023		Traceability #	1A0C15R12101	Calibrated by:	DPL
Buffer #:	7.00	NRE19092702		9/2023		pH:	7.51	Calibration Time:	1130
Buffer #:	10.00	NRE19092702		9/2020		Turb:		Calibration Date:	22 Apr 20
Turbidity Meter Calibration Info		Standard Traceability #		Exp. Date				Calibration Temp:	
Standard #	802	19360099		3/2021					
Standard #	100	19360100		3/2021					
Standard #	200	19360101		3/2021					
Standard #	0.02	19360172		3/2021					

Notes:

Chain of Custody Record/ Analysis Report

(205) 699-3882 Fax
www.gsilab.com

[illegible]

Chain of Custody Record/ Analysis Report

(205) 699-3882 Fax
www.qsilab.com

[illegible]

Guardian Systems, Inc.

1108 Ashville Road, P.O. Box 190
Leeds, Alabama 35094
(205) 699-6647
email: gsi@gsilab.com

Chain of Custody Record/ Analysis Report

(205) 699-3882 Fax
www.gsilab.com



Client: Mr. Brad Watson		Phone:	
Company: City of Leeds		Fax:	
Address: 1040 Park Drive		P.O.#:	
Leeds, AL 35094		Project: 2020 1st Semester Stormwater-Dry	

Sample ID	Sample Description	Sample Date	Sample Time	Sample Preservative						Analysis Requested							
				Comp. *	Grab	Glass	Plastic	HCl	HNO ₃	H ₂ SO ₄	NaOH	Cool 4°C	Other **	Field pH:	Field Turbidity:	Field Conductivity:	APHA Color
LC 551		4/22	7:46														
			12:39														
			8:00														
			2:45 PM	X										X			
				X										X			
				X										X			
LC 559			7:11														
		4/22	12:30														
			01:00														
			2:45 PM	X										X			
				X										X			
				X										X			

Sampled by: Dennis P. Lyons	Relinquished by: Dennis P. Lyons	Date: 22 Apr 20	Time: 15:25
Received by:	Relinquished by:	Date:	Time:
Received by:	Relinquished by:	Date:	Time:
Received for Laboratory by: Lisa Pongman	Date: 22 Apr 20	Time: 15:25	
Was Shipped Container intact when received? Yes ☒ No ☐	Initials LP	Seals intact? Yes ☒ No ☐	
Were all samples properly preserved? Yes ☒ No ☐	Initials LP	Sample temp. 6 °C	

Comments: Other = See Above for Sample Preservatives, Field Measurements			
PH Meter Calibration Info	Buffer Traceability #	Exp. Date	QC Sample
Buffer #:			Calibrated by:
Buffer #:			Calibration Time:
Buffer #:			Calibration Date:
Turbidity Meter Calibration Info	Standard Traceability #	Exp. Date	Calibration Temp:
Standard #			
Standard #			
Standard #			

Notes:



Chain of Custody Record/ Analysis Report

1108 Ashville Road, P.O. Box 190
Leeds, Alabama 35094
(205) 699-6647
email: gsi@gsilab.com

(205) 699-3882 Fax
www.gsilab.com

[illegible]